

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/2021/School/WZ/ 865

Dated: 21/10/2021

FIRE SAFETY CERTIFICATE

Certified that the N. K. Bagrodia Public School, Sector-09 Rohini, Delhi-110085, comprised of **Basement+ Ground + Three upper floors** owned/occupied by N. K. Bagrodia Public School, has already been issued FSC by this department vide letter No. F.6/DFS/MS/2017/School/1821 dated 15.12.2017. The premises were re-inspected by the officer concerned of this department on 07.09.2021 in the presence of Sq. Ldr (Retd.) P.K Slawan, Admin Officer and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premises have therefore deemed complied with the requirements of NBC Part-IV and building /premise is fir for occupancy under Educational "Group B" with effect from 21/10/2021 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 21.10.2021. at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to:-

1. N. K. Bagrodia Public School, Sector-09, Rohini, Delhi-110085,
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No F 6/DFS/MS/2021/School/WZ | 449

Dated: 7 / 7 / 2021

FIRE SAFETY CERTIFICATE

Certified that the N. K. Bagrodia Public School, (Nursery School Building), Plot No.1, Sector-25, Rohini, Delhi-85 comprised of Gr.+ One upper floor owned/occupied by N. K. Bagrodia Public School was granted FSC by this department vide letter No. F.6/DFS/MS/2018WZ/1205 dated 23.05.2018. The premises was re-inspected by the officer concerned of this department on 23.06.2021 in the presence of Sh. P. K. Salwan (Admin Officer) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from7./7./21..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ..7./7./21..... at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, N. K. Bagrodia Public School, Plot No.1, Sector-25, Rohini, Delhi-85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6/DFS/MS/2021/School/WZ / 473

Dated: 3/7/2021

FIRE SAFETY CERTIFICATE

Certified that the N.K. Bagrodia Public School (Nursery School building) located at Plot No. 2, Sector-25, Rohini, Delhi-110085 comprised of ground and 01 upper floors owned/ occupied by the N.K. Bagrodia Public School was issued fire safety certificate vide this office letter no. F.6/MS/DFS/MS/2018/School/WZ/994 Dated: 10.05.2018. The premises was re-inspected by the officer and observed that the school have deemed complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 28.06.2021 in the presence of Sh. P.K.Salwan (Admin officer) and that the building/premises is fit for occupancy Group B Educational for ground and first floor only with effect from ...13/7/21..... for a period of three years subject to compliance of the conditions mentioned below:

Issued on13/7/21..... at New Delhi


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, N.K. Bagrodia Public School, Plot No. 2 Sector-25, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in